

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. PH-2025/174

Date : 14-05-25

It is certified that an inspection team headed by Dr. Dinesh Kumar
Dy. Civil Surgeon (Health), Narnaul (Name of Officers
with designation) from Health (Name of
Department/Office) inspected the M.R. Public School, Tajpur mod,
Ateli Mandi, Dist. Mahendragar (Haryana) (Name & Address of
the School) on 12/05/25 and found that the M.R. Public School
Tajpur mod, Ateli Mandi (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 (one year)

Signature with Seal : [Signature]
Name : Dy. CS (Health)
Designation : For Civil Surgeon, Narnaul

To
Principal, M.R. Public School
Tajpur mod, Ateli Mandi
Mahendragar (Haryana)
(Name & Address of the Institution)

[Signature]
For Maru Ram Dehat
Bal Vikash Shiksha Samiti
President



PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY, NARNAUL
NARNAUL (HR)



TEST REPORT

Test Report No. : PC- 790	Issue Date:- 04.06.2024
Issued to : President	Location:- Tube Well
Your Reference No. : MHD/01630/05/2024	Collected by: - Siya Ram
Sample Type : Water	Sample collected date: - 30.05.2024
Name of person : Siya Ram	Sample received on: - 30.05.2024
Lab Job Order No. : 790	Sample Quantity: 1 Ltr.
Address : M.R Public School Tajpur, Ateli Mandi	Contact No.: 9416414945

S. No.	Parameter	Results	IS:10500:2012 (RA-2018)		Unit
			Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved Solids (TDS)	730	500	2000	mg/L
2	Iron (Fe)	0.10	1.0	1.0	mg/L
3	Sulphate (SO_4^{2-})	60	200	400	mg/L
4	Nitrate	2.4	45	45	mg/L
5	Turbidity	0.90	1	5	NTU
6	Colour	05	5	15	Hazen
7	pH	7.33	6.5	8.5	-

Continued On Next Page

Signature

Signature

President

Maru Ram Dehat Bal Vikash Siksha Sam.
Shaharpur



**PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY
NARNAUL (HR)**

PHED
Haryana
PHEDNNL7.8 F02

Test Report No. : PC- 790	Issue Date:- 04.06.2024
Issued to : President	Location:- Tube Well
Your Reference No. : MHD/01630/05/2024	Collected by: - Siya Ram
Sample Type : Water	Sample collected date: - 30.05.2024
Name of person : Siya Ram	Sample received on: - 30.05.2024
Lab Job Order No. : 790	Sample Quantity: 1 Ltr.
Address : M.R Public School Tajpur, Ateli mandi	Contact No.: 9416416945

RESULTS


S. No.	Parameter	Protocol Used	Results	IS:10500:2012(RA-2018)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
8	Total Hardness(as CaCO_3)	APHA 23 rd edition 2340 C	150	200	600	mg/L
9	Calcium (as Ca)	APHA 23 rd edition 3500-Ca B	20.04	75	200	mg/L
10	Magnesium (as Mg)	APHA 23 rd edition 3500 Mg B	24.3	30	100	mg/L
11	Chloride (as Cl)	APHA 23 rd edition 4500 Cl- B	189.97	250	1000	mg/L
12	Total Alkalinity(as CaCO_3)	APHA 23 rd edition 2320 B	110	200	600	mg/L
13	Taste	IS:3025 Part 8	Agreeable	Agreeable	Agreeable	-
14	ODOUR	IS:3025 Part 5	Agreeable	Agreeable	Agreeable	-
15	Fluoride	APHA 23 rd edition 4500-F - D	0.98	1.0	1.5	mg/L


Opinion: The parameter tested at Sr.No. 1-15 in the test report meets the requirement of IS 10500:2012 (RA- 2018). The above water sample of sample descriptions M.R Public School Tajpur chemically Fit on the Above Parameters

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Narnaul. Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by: Vikas


Sudhir Chaudhary
Authorized Signatory/QM


President
Maru Ram Dehat Bal Vikash Siksha Samiti
Shaharpur



PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY, NARNAUL
NARNAUL (HR)



To,

The President
M.R Public School School
Tajpur, Ateli Mandi.

Memo No. 1432

Date: 04/06/2024

Subject:-

BACT – EXAM REPORT OF WATER SAMPLE

Person who collected sample: - Siya Ram


Sample collection Date :- 30/05/2024


Sample Receipt Date:- 30/05/2024

Sr. No.	Sample ID	SOURCE OF SAMPLE	NO. OF COLIFORM	No. of Feecal	RESULT
01	MHD/01641/5/2024	Tube Well	0	0	Fit

The above sample is Fit for Human consumption.

Reliability of water sample lies with sender / collector of water sample.


Sudhir Chaudhary
Authorized Signatory/QM


President
Maru Ram Dehat Bal Vikas Siksha Sam
Shaharpur